



B6 Dual-Sensor Gas Transmitter



BACnet Protocol Implementation Conformance (PIC) Statement

QUATROSENSE ENVIRONMENTAL LTD.
5935 OTTAWA STREET, PO BOX 749 (RICHMOND) OTTAWA, ONTARIO CANADA K0A 2Z0
PHONE: (613) 838-4005 FAX: (613) 838-4018
www.QELsafety.com

ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE)

B6 BACnet Protocol Implementation Conformance Statement

Date: 2017-12-06

Vendor Name: Quatrosense Environmental Ltd

Product Name: B6 Gas Transmitter

Product Model Number: B6-MAC:-xxx

Application Software Version: B6-BMCU-1-01

Firmware Revision: B6-BMCU-1-01

BACnet Protocol Revision: Version 1, Revision 7

Product Description:

B6 is a Dual sensors in one Gas Transmitter that communicates via BACnet protocol MS/TP. B6 is an end device in term of BACnet protocol. Available with electrochemical sensor to detect toxic gases, catalytic sensor to detect combustible gases and NDIR infrared sensor to detect CO2 and CH4.

BACnet Standardized Device Profile (Annex L):

- ☐ BACnet Operator Workstation (B-OWS)
- ☐ BACnet Advanced Operator Workstation (B-AWS)
- ☐ BACnet Operator Display (B-OD)
- ☐ BACnet Building Controller (B-BC)
- ☐ BACnet Advanced Application Controller (B-AAC)
- ☐ BACnet Application Specific Controller (B-ASC)
- ☒ BACnet Smart Sensor (B-SS)
- ☐ BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K):

BIBB-Data sharing-ReadProperty-B (DB-RP-B)

BIBB-Data sharing-ReadPropertyMultiple-B (DB-RPM-B)

BIBB-Data sharing-WriteProperty-B (DB-WP-B)

BIBB-Device Management-Device Communication Control-B (DM-DCC-B)

BIBB-Device Management-TimeSynchronization-B (DM-TS-B)

BIBB-Device Management-UTCTimeSynchronization-B (DM-UTC-B)

Segmentation Capability:

- ☐ Able to transmit segmented messages Window Size _____
- ☐ Able to receive segmented messages Window Size _____

Standard Object Types Supported:

Device Object

Analog Input Object

Binary Value Object

Binary Output Object

Data Link Layer Options:

- ☐ BACnet IP, (Annex J)
- ☐ BACnet IP, (Annex J), Foreign Device
- ☐ ISO 8802-3, Ethernet (Clause 7)
- ☐ ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ☐ ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s) _____
- ☒ MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- ☒ MS/TP slave (Clause 9), baud rate(s): 9600, 19200, 38400, 76800
- ☐ Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- ☐ Point-To-Point, modem, (Clause 10), baud rate(s): _____
- ☐ LonTalk, (Clause 11), medium: _____
- ☐ BACnet/ZigBee (ANNEX O)
- ☐ Other: _____

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) ☐ Yes ☒ No

Networking Options:

- ☐ Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- ☐ Annex H, BACnet Tunneling Router over IP
- ☐ BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? ☐ Yes ☒ No
 - Does the BBMD support network address translation? ☐ Yes ☒ No

Network Security Options:

- ☒ Non-secure Device - is capable of operating without BACnet Network Security
- ☐ Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
 - ☐ Multiple Application-Specific Keys:
 - ☐ Supports encryption (NS-ED BIBB)
 - ☐ Key Server (NS-KS BIBB)

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- | | | |
|---|---|-------------------------------------|
| ☒ ANSI X3.4 | ☐ IBM™/Microsoft™ DBCS | ☐ ISO 8859-1 |
| ☐ ISO 10646 (UCS-2) | ☐ ISO 10646 (UCS-4) | ☐ JIS X 0208 |

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

ANNEX K – BACnet INTEROPERABILITY BUILDING BLOCK (BIBBs) (NORMATIVE)**K.1.2 BIBB – Data Sharing – ReadProperty – B (DS-RP-B)**

The B device is a provider of data to device A

BACnet Service	Initiate	Execute
ReadProperty		X

K.1.4 BIBB – Data Sharing – ReadPropertyMultiple – B (DS-RPM-B)

The B device is a provider of data to device A and returns multiple values at one time.

BACnet Service	Initiate	Execute
ReadPropertyMultiple		X

K.1.8 BIBB – Data Sharing – WriteProperty – B (DS-WP-B)

The B device is a provider of data to device A.

BACnet Service	Initiate	Execute
WriteProperty		X

K.5.2 BIBB – Device Management – Dynamic Device Binding – B (DM-DDB-B)

The B device provides information about its device attributes and responds to requests to identify itself.

BACnet Service	Initiate	Execute
Who-Is		X
I-Am	X	

K.5.4 BIBB – Device Management – Dynamic Object Binding – B (DM-DOB-B)

The B device provides address information about its objects upon requests.

BACnet Service	Initiate	Execute
Who-Has		X
I-Have	X	

K.5.6 BIBB – Device Management – DeviceCommunicationControl – B (DM-DCC-B)

The B device responds to communication control exercised by the A device.

BACnet Service	Initiate	Execute
DeviceCommunicationControl		X

K.5.12 BIBB – Device Management – TimeSynchronization – B (DM-TS-B)

The B device interprets time synchronization messages from the A device.

BACnet Service	Initiate	Execute
TimeSynchronization		X

K.5.13 BIBB – Device Management – UTCTimeSynchronization – B (DM-UTC-B)

The B device interprets time synchronization messages from the A device.

BACnet Service	Initiate	Execute
UTCTimeSynchronization		X

Property List of Objects

Device:

*Note: all string size should be less than 20 characters.

Property	Default Value	Access	Conformance Code
object-identifier	device, 4005	Read/Write	Required
object-name	"B6-MAC: (address)"	Read/Write	Required
object-type	device	Read	Required
system-status	operational	Read	Required
vendor-name	"QEL (Quatrosense Environmental Ltd)"	Read	Required
vendor-identifier	464	Read	Required
model-name	"B6-MAC: (address)"	Read	Required
firmware-revision	"B6-BMCU-x-xx"	Read	Required
application-software-version	"B6-BMCU-x-xx"	Read	Required
Location	"Canada"	Read/Write	Optional
description	"B6 MAC: (address) (gas_type1)(gas_type2)"	Read/Write	Optional
protocol-version	1	Read	Required
protocol-revision	7	Read	Required
protocol-services-supported	ReadProperty, ReadPropertyMultiple WriteProperty, DeviceCommunicationControl ReinitializeDevice, TimeSynchronization Who-has, Who-is, UTCTimeSynchronization	Read	Required
protocol-object-types-supported	device, analog-input, binary-output, binary-value	Read	Required
object-list	Device, 4005 Analog Input 0 (B6M Gas Concentration) Analog Input 1 (B6M STEL) Analog Input 2 (B6M TWA) Analog Input 3 (B6M Daily Peak) Analog Input 4 (B6M MCU Temperature) Analog Input 5 (Q6R Gas Concentration) Analog Input 6 (Q6R STEL) Analog Input 7 (Q6R TWA) Analog Input 8 (Q6R Daily Peak) Analog Input 9 (Q6R MCU Temperature) Binary Value 0-7 (B6M Alarm1 to Alarm8) Binary Value 8-15 (Q6R Alarm1 to Alarm8) Binary Output 0-2 (Relay1 to Relay3) Binary Output 3-5 (Buzzer1 to Buzzer3)	Read	Required
max-APDU-length-accepted	480	Read	Required
segmentation-supported	NO-SEGMENTATION	Read	Required
apdu-timeout	3000 (ms)	Read	Required
number-of-apdu-retries	3	Read	Required
device-address-binding	()	Read	Required
database-revision	1	Read	Required
max-master	127	Read/Write	Required
max-info-frames	1	Read/Write	Required
Local_Time	Time	Read	Optional
Local_Date	Date	Read	Optional
UTC_Offset	Integer	Read	Optional
Daylight_Savings_Status	Boolean	Read	Optional

Analog Input 0:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 0	Read	Required
object-name	"B6M Concentration"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Instantaneous Reading"	Read/Write	Optional

Analog Input 1:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 1	Read	Required
object-name	" B6M STEL "	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Short Term Exposure Limit"	Read/Write	Optional

Analog Input 2:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 2	Read	Required
object-name	" B6M TWA "	Read	Required
object-type	analog-input(0)	Read	Required
present-value	xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	false	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Time Weighted Average"	Read/Write	Optional

Analog Input 3:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 3	Read	Required
object-name	“ B6M Daily Peak”	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	“24 Hours Peak Reading”	Read/Write	Optional

Analog Input 4:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 4	Read	Required
object-name	“ B6M MCU Temperature”	Read	Required
object-type	analog-input(0)	Read	Required
present-value	xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	false	Read/Write	Required
units	Degrees-Celsius	Read	Required
description	“ B6M Microcontroller Temperature”	Read/Write	Optional

Analog Input 5:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 0	Read	Required
object-name	"Q6R Concentration"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Instantaneous Reading"	Read/Write	Optional

Analog Input 6:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 1	Read	Required
object-name	"Q6R STEL"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Short Term Exposure Limit"	Read/Write	Optional

Analog Input 7:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 2	Read	Required
object-name	"Q6R TWA"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	false	Read/Write	Required
units	Parts-per-million	Read	Required
description	"Time Weighted Average"	Read/Write	Optional

Analog Input 8:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 3	Read	Required
object-name	"Q6R Daily Peak"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	Xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
units	Parts-per-million	Read	Required
description	"24 Hours Peak Reading"	Read/Write	Optional

Analog Input 9:

Property	Default Value	Access	Conformance Code
object-identifier	analog-input, 4	Read	Required
object-name	"Q6R MCU Temperature"	Read	Required
object-type	analog-input(0)	Read	Required
present-value	xxxx	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	false	Read/Write	Required
units	Degrees-Celsius	Read	Required
description	"Q6R Microcontroller Temperature"	Read/Write	Optional

Binary Value 0 to Binary Value 7:

Property	Default Value	Access	Conformance Code
object-identifier	binary-value, 0 - 7	Read	Required
object-name	"B6M Alarm1 to Alarm8 Status"	Read	Required
object-type	binary-value(5)	Read	Required
present-value	active / inactive	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
description	"BV(x): Alarm1 Status"	Read/Write	Optional
priority-array	B6 priority is 12	Read	Optional
relinquish-default	inactive	Read	Optional

Binary Value 8 to Binary Value 15:

Property	Default Value	Access	Conformance Code
object-identifier	binary-value, 8 – 15	Read	Required
object-name	"Q6R Alarm1 to Alarm8 Status"	Read	Required
object-type	binary-value(5)	Read	Required
present-value	active / inactive	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
description	"BV(8+x): Alarm(x) Status"	Read/Write	Optional
priority-array	B6 priority is 12	Read	Optional
relinquish-default	Inactive	Read	Optional

Binary Output 0 to Binary Output 2:

Property	Default Value	Access	Conformance Code
object-identifier	binary-output, 0 - 2	Read	Required
object-name	"Relay1 to Relay3 Status"	Read	Required
object-type	binary-output(4)	Read	Required
present-value	active / inactive	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
Priority	normal	Read	Required
Description	"BO(x): Relay(x) Output"	Read/Write	Optional
priority-array	B6 priority is 12	Read	Required
relinquish-default	inactive	Read	Required

Binary Output 3 to Binary 5:

Property	Default Value	Access	Conformance Code
object-identifier	binary-output, 3 - 5	Read	Required
object-name	"Buzzer1 to Buzzer3 Status"	Read	Required
object-type	binary-output(4)	Read	Required
present-value	active / inactive	Read/Write	Required
status-flag	health / overridden	Read	Required
event-state	normal(0)	Read	Required
out-of-service	False	Read/Write	Required
priority	normal	Read	Required
description	"BO(3+x): Buzzer(x) Output"	Read/Write	Optional
priority-array	B6 priority is 12	Read	Required
relinquish-default	Inactive	Read	Required