



UKCA Declaration of Conformity (DoC)

Manufacturer's Name: Automation Components Inc.

Manufacturer's Address: 2305 Pleasant View Rd
Middleton, WI 53562 USA

Date of Issue: 11/01/2022

Equipment: Differential Pressure Transmitter: A/MLP2 Series

Model Numbers: **A/MLP2-CCC-D-E-F-G-HH**
A - Can be any letter indicating customer abbreviation for documentation' A = ACI
CCCC - Indicated differential pressure range
D - Units of pressure range (W = inches of Water Column; P = Pascals)
E - Range type of unit (B = Bi-directional; U = Uni-directional)
F - Unit accuracy (A = $\pm 0.5\%$; B = $\pm 0.25\%$)
G - Output signal (A = 4 to 20 mA; B = 0 to 5 VDC; C = 0 to 10 VDC)
HH - NIST certification (OP = No NIST Certificate; 3P = 3 Point NIST Certificate
5P = 5 Point NIST certificate)

Directives: RoHS SI 2012 No. 3032
EMC SI 2016 No. 1091

Standards: BS EN IEC 61326-1:2021

Tested By: Intertek Testing Services NA, Inc.
40 51st Way NE, Suite 100
Fridley, MN 55421

Automation Components Inc declares that to its knowledge, as of the date of this document, the products listed above conform to the requirements of the United Kingdom's Restriction of Hazardous Substances (RoHS) Directive SI 2012 No. 3032.

We hereby certify that the apparatus described above conforms to the essential requirements and provisions of the EMC Directives.

Signature:  Title: VP Product Development

Date: 11/01/2022

“Engineering a Better Sensor Solution”