



## EU Declaration of Conformity (DoC)

**Manufacturer's Name:** Automation Components Inc.

**Manufacturer's Address:** 2305 Pleasant View Rd  
Middleton, WI 53562 USA

**Date of Issue:** 12 April 2018

**Equipment:** Differential Pressure Transmitter A/MLP Series

**Model Numbers:** **A/MLP2-CCC-D-E-F-G-HH**  
A – Can be any letter indicated customer abbreviation for documentation; A= ACI  
CCCC – Indicated differential pressure range  
D – units of pressure range (W = inches of Water Column; P = Pascals)  
E – range type of unit (B = Bi-Directional; U = Uni-Directional)  
F – unit accuracy (A =  $\pm 0.5\%$ ; B =  $\pm 0.25\%$ )  
G – Output signal (A = 4 to 20 mA; B = 0 to 5 VDC; C = 0 to 10 VDC)  
HH – NIST certification ( 0P = No NIST; 3P = 3 point; 5P = 5 point)

**Directives:** **RoHS2 2011/65/EU**  
**EMC 2014/30/EU**

**Standards:** EN 61326-1:2012

**Evaluated By:** Intertek Testing Services NA, Inc.  
7250 Hudson Blvd., Suite 100  
Oakdale, MN 55128 USA  
Report: 103454996MIN-001

Based on the information derived from our supplier material declarations and our own verification system, Automation Components, Inc. declares that the following list of parts do not exceed the maximum concentration levels of substances mentioned above per homogeneous material, unless allowed in the Application Exemptions listed in the Annex of the RoHS2 Directive.

We hereby certify that the apparatus described above conforms to the essential requirements and provisions of the EMC Directives.

Signature: Bill Kubog Title: Engineering Manager Date: 11 Sep 2018