



UKCA Declaration of Conformity (DoC)

Manufacturer's Name: Automation Components Inc.

Manufacturer's Address: 2305 Pleasant View Rd
Middleton, WI 53562 USA

Date of Issue: 11/01/2022

Equipment: Differential Pressure Transmitter: A/DLP Series

Model Numbers: **DLP-WWW-U-B-D-A-P-O-N-E**
WWW = pressure range
U = Display units setting in WC (W) or Pascals (P).
B = setting for bi-directional (B) or unidirectional (U) ranges
D = Display or no display included with unit; N – no display, D – display
A = calibration accuracy level
P = Packaging options: inclusion of housing attachments pitot tube and/or din rail clip; 0) no options; 1) pitot tube included; 2) din rail clip included; 3) both pitot tube and din rail clip
O = Output mode setting: A) 4-20 mA, B) 0-5 VDC, C) 0-10 VDC.
N = NIST certification documentation included or not:
E = enclosure style:

Directives: RoHS SI 2012 No. 3032
EMC SI 2016 No. 1091

Standards: BS EN IEC 61326-1:2021

Tested By: Intertek Testing Services NA, Inc.
40 51st Way NE, Suite 100
Fridley, MN 55421

Automation Components Inc declares that to its knowledge, as of the date of this document, the products listed above conform to the requirements of the United Kingdom's Restriction of Hazardous Substances (RoHS) Directive SI 2012 No. 3032.

We hereby certify that the apparatus described above conforms to the essential requirements and provisions of the EMC Directives.

Signature:  Title: VP Product Development

Date: 11/01/2022

“Engineering a Better Sensor Solution”